



Description

KENTEC Sigma A-XT releasing panel offers outstanding value and performance for all small to medium fixed firefighting installations. With three initiation circuits as standard, release can be configured to activate from any combination of detection zone inputs to allow (among other combinations) any two from three types of activations.

Specification

Construction	1.2mm mild sheet steel
IP rating	IP30
Finish	Epoxy powder coated
Colour- lid & box	Red RAL 3002 (optional grey BS 00 A 05 semi-matt)
Mains supply	230V AC or 115V AC
Mains supply fuse	1.6Amp (FL.6A L250V)
Power supply rating	3 Amps total including battery charge 28V +/- 2V
Maximum ripple current	200 millivolts
Battery Type (Yuasa NP)	Two 12 Volt 7Ah sealed lead acid in series
Battery charge voltage	27.6VDC nominal (temperature compensated)
Battery charge current	0.7A maximum
Battery fuse	20mm, 3.15A glass